


TEST REPORT

Accredited by **NABL** (Chemical & Biological)
Recognized by **BIS** as per IS : 14543 : 2016

Report No :	ECI-WT-2026/01/112	Report Date :	03.02.2026
Customer Name & Address	M/s. BBW S.F.No:322/1A3, Moperipalayam Road, Thanneer Pandal, Karumathapatti Via, Near Annalakshmi Garden, Moperipalayam Village, Coimbatore-641659.		
Customer Reference :	IWO Date: 27.01.2026	Sample Reference No :	ECI-WT-2026/01/112
Sample Drawn By :	ECI	Sample Received On :	27.01.2026
Sample Collected Date :	27.01.2026	Test Commenced On :	27.01.2026
Qty of Sample Received :	1 Ltr	Test Completed On :	03.02.2026
Sample Description :	Treated Water	Sampling Method :	IS:3025
Sample Mark:	STP Outlet Water		


S.No	PARAMETERS	UNITS	RESULTS	TEST METHOD	Max. Permissible CPCB norms
1	pH	-	7.2	IS 3025(Part 11)	6.5 - 8.5
2	Bod (3days at 27°C)	mg/L	18	IS 3025(Part 44)	≤ 20
3	COD	mg/L	45	IS 3025 (Part 58)	≤ 50
4	Total Suspended Solids (TSS)	mg/L	18	IS 3025 (Part 17)	≤ 30
5	Oil & Grease	mg/L	<1.0	IS 3025 (Part 39)	≤ 10
6	Ammoniacal Nitrogen (as N)	mg/L	5.0	IS 3025 (Part 34)	≤ 50
7	Total Nitrogen	mg/L	12	APHA 4500-N	≤ 50
8	Fecal Coliform	MPN/100ml	<10	IS 1622	≤ 100

<--- End of Report --->

Verified By : 

Remarks : In the above mentioned stack meets the requirements of TNPCC standards with respect to the parameters tested
NA - Not Applicable

For ENVIRO CARE INDIA PRIVATE LIMITED
(Laboratory Division)


Authorized Signatory



43, 2nd Street, Harvey Nagar, Arasaradi, Madurai - 625 106. Tel : +91 452 4355103

Note : 1. The results relate only to this item tested.

2. Any correction not attested shall invalidate this report.

3. Report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.

4. Unless informed by customer, the test items will not be retained for more than 15 days from date of issue of test report.

5. Total liability of our laboratory is limited to the Invoice amount.

6. Any dispute arising out of this report is subjected to Madurai Jurisdiction Only.

